

Certificate of Accreditation

Amendment 4

Name of product:	STATEWALL EXTERNAL WALL CLADDING SYSTEM
Product description:	External wall cladding system
Description of the purpose and use of the building product:	Suitable for use as an external wall cladding system on Class 1 and Class 10 buildings.
Regulation/s in relation to which the building product is accredited:	<p>The Building Regulations Advisory Committee appointed under Division 4 of Part 12 of the Building Act 1993 has examined the application and accredited the product as complying with;</p> <p>Performance Requirement H1P1, H2P2, H2P3 of the National Construction Code 2022 Series, Volume Two, Building Code of Australia, Class 1 and Class 10 buildings as adopted by the Building Regulations 2018, to the extent that those clauses refer to the structural performance of external walls, resistance to wind action and rainwater action, and weatherproofing, and damp-proofing, of external wall systems, subject to the following conditions:</p>
Conditions to which the accreditation is subject:	<ol style="list-style-type: none">1. The accreditation is limited to Class 1 and associated Class 10 buildings in wind classes N1 to N3, with geometric limits set out in clause 1.2, of AS 4055-2021 Wind loads for housing, as amended from time to time, in particular:<ul style="list-style-type: none">• the distance from averaged ground level to the underside of eaves must not exceed 6.0m;• the distance from averaged ground level to the highest point of the roof, not including chimneys, must not exceed 8.5m;• the width including roofed verandas, excluding eaves up to a maximum of 0.9m, shall not exceed 16.0m, and the length must not exceed 5 times the width; and• the roof pitch must not exceed 35°.2. Installation must be in accordance with the StateWall External Wall Cladding System Technical and Installation Manual, Edition 7 dated November 2024, except that project specific flashing and cavity drainage details must be to the satisfaction of the relevant building surveyor.3. The risk score must be 20 or less, when the sum of all risk factor scores are determined in accordance with BCA Volume Two Table H2V1a.4. The relevant part of the external wall must only include windows that comply with AS 2047.

Building

Regulations Advisory Committee

5. The system must be installed on timber or steel framing, complying with AS 1684.2 Residential Timber-Framed Construction – Non-cyclonic areas, or NASH Standard - Residential and Low-Rise Steel Framing Part 1 or 2, as appropriate and as amended from time to time, with studs at a maximum spacing of 600 mm centre to centre.
6. The sarking to be installed as part of the system must be breathable sarking.
7. Panel to timber batten fasteners must be installed with a minimum embedment depth of 25mm.
8. All fixtures and features attached to the wall must be secured into the wall framing.
9. The system must be installed a minimum of 75 mm from any finished external ground surface.
10. Render must be applied strictly in accordance with the manufacturer's installation requirements.

The name, address and Australian business number of the holder of the accreditation: Allstate Polystyrene Industries
11 Pascal Road
SEAFORD VIC 3198
ABN: 39 154 846 116

Certificate number: V18/01-A4

Date of issue: 28/03/2025

Refer to the Historical Details page of this Certificate.
This Certificate is only valid when reproduced in its entirety.

Date of expiry of accreditation: 28/03/2028

Signature:



Heidi Smith
Nominated Chair, Building Regulations Advisory Committee

Building

Regulations Advisory Committee

Practitioner guidance on how to use a Certificate of accreditation

Practitioners are reminded to consider any limitations noted in this Certificate and whether the performance of the product has been tested for all aspects of the performance that it is expected to achieve in the application it is being applied to.

This accreditation is only valid in the State of Victoria.

Historical Details

Certificate number:	Description:	From:	To:
V18/01	Accreditation granted	21 November 2018	-
V18/01-A1	Amendment to Certificate details: <ul style="list-style-type: none">Change of address of owner and reference to updated manual	19 December 2018	-
V18/01-A2	Amendment to Certificate details: <ul style="list-style-type: none">Change of product name and reference to updated manual	01 July 2019	-
V18/01-A3	Amendment to Certificate details: <ul style="list-style-type: none">Reaccreditation granted for a period of 3 yearsReference to new product manual (Edition 5, February 2022)New Certificate number issued	28 March 2022	28 March 2025
V18/01-A4	Amendment to Certificate details: <ul style="list-style-type: none">Reaccreditation granted for a period of 3 yearsPerformance Requirements updated to reflect NCC 2022 Volume 2.Reference to new product manual (Edition 7, November 2024)New Certificate number issued	28 March 2025	28 March 2028